

SAFE DRINKING WATER AND SANITARY CONDITIONCERTIFICATE

NO:.....144.....

Date: ..26/5/25..

It is certified that an inspection team headed by
 Dr. R.N. Choudhary.....from.....M.O.....(Designation) Purnea
 inspected the **Greenfield Public School Harda, Purnea** on.....22/5/25.....
 and found that the Greenfield Public School has safe water drinking facilities
 for the students and members of staff of the institution and is maintaining the
 hygienic sanitation condition in the school building & the campus as per the
 norms prescribed the central/State/U.T Govt.

The above valid for a period of.....TWO YEARS.....

Signature with seal :.....
 26/5/25
 पञ्चम प्रभुपति

Name :.....Dr. R.N. Choudhary.....

Designation :.....Medical Officer.....

TO,

Greenfield public school

N.H-31, Harda,Purnea

Pin-854303

Government of Bihar
Public Health Engineering Department
 Water Quality Testing Report
 Sample Given By Bikesh Kumar

District Name: Purnea

Division Name: P.H. Division, Purnea

Month: April, 2025

Sl. No.	Block	Panchnyat	Village/Habitation	Location of source	Type of source	Parameters											Remarks
						pH	Turb.	EC	TDS	TH	Cl	Alka	Fe	Ca	Mg		
1	Purnea East	Nagar Nigam	Harla N.H-31	Greenfield Public School	Tap Water	7.1	3.0	303	152	117.6	30.39	98	0.5	39.2	4.75	इस रिपोर्ट में दर्शाए गए परिणामों के द्वारा ज्ञात होता है कि इस नमूने की गुणवत्ता को सुरक्षित माना जा सकता है। यदि आवश्यक हो तो और नमूने के लिए	
Desirable Limit*						6.5-8.5	5.0	-	500	200	250	200	1.0	75	30		
Permissible Limit* in absence of alternate source						NR	10.0	-	2000	600	1000	600	NR	200.0	100		

Shyam
 21/04/25
 Chemist

Prof. 21/4/25
 A.E.
 P.H. Sub Division, Purnea

21.04.25
 Executive Engineer
 P.H. Division, Purnea